
ELECTRICAL SAFETY CHECKLIST

TERMS OF USE

This checklist is intended for use only when both of the following conditions apply

- EICR was done in last 5 years
- Required actions on the EICR has been done

NAME

DATE OF INSPECTION

ADDRESS

CHECKLIST OVERVIEW

Note the risk and where it is located

Specify the action to be performed

1	<input type="text"/>
2	<input type="text"/>
3	<input type="text"/>
4	<input type="text"/>
5	<input type="text"/>
6	<input type="text"/>

<input type="text"/>
<input type="text"/>
<input type="text"/>
<input type="text"/>
<input type="text"/>
<input type="text"/>

COMMENTS

FUSEBOX

- All covers are correctly positioned and securely attached (a damaged cover could present a shock or fire hazard)
- The Residual Current Device (RCD) trips when the test (or 'T') button is pressed
- Flammable materials are not stored on or near the Fusebox

SOCKETS AND LIGHTS

- Sockets, lights, and switches are firmly attached and in proper condition
- Sockets, lights, and switches show no evidence of excessive heat
- Flexible cables are not placed where they are likely to be damaged
- Sockets are not overloaded with an excessive number of devices


ELECTRICAL APPLIANCE

- Appliances are not affected by a product recall
- All covers are correctly positioned and in acceptable condition
- Flexible cables are in acceptable condition and show no signs of wear
- Flexible cables are firmly secured to the appliance and plug

ADDITIONAL CHECKS

- Smoke detector activates when the test button is pressed
- Carbon monoxide detector activates when the test button is pressed

All of the EICR testing and inspections that we conduct are carried out by either the NICEIC, NAPIT or ECA registered Engineers who have a minimum of 5 years' experience in the industry.



0191 743 1448
info@londonpropertyinspections.co.uk